

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7125-0785:128 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Wheelock Inc., 273 Branchport Ave., Long Branch NJ 07740  
Contact: Luy Nguyen (732) 222-6880

**DESIGN:** Multitone audible/visual signal devices Models AMT-12, AMT-24, AMT4-12, and AMT4-24, followed by -LS, -LSM, -MS, -IS, -HSPW. \*Models ATM-24 or ATM-4-24, followed by -SL, -SLM or -SHPW.

Unit may follow by suffixes to designate lens orientation, lettering and plate color. Models AMT, AMT4 are switchable between nominal 12 and 24 VDC with high and low output. This series can provide one of nine tone outputs. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Electrical: -12: 10.5 - 15.6 VDC, 60 flashes per minute  
-24: 20 - 31 VDC, 60 flashes per minute

Strobe Candela: -LS, -SL: 15 cd  
-LSM, -SLM: 15/75 cd  
-MS: 30 cd  
-IS: 75 cd  
-HSPW, -SHPW: 110 cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to authority having jurisdiction.

**MARKING:** Listee's name, model number, rating and UL label.

**APPROVAL:** Listed as audible/visual signal devices for use with separately listed compatible control units. For indoor use only. Models LS, MS, IS or SL strobes are for wall or ceiling mount; and Models LSM, SLM, HSPW and SHPW strobes are for wall mount only. Models using **SL**, **SLM** and **SHPW** strobes must employ the use of sync control module Model SCM-24.

\*These appliances can produce a distinctive three pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition.

\*Corrected 08-27-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**APRIL 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager